







BOLIS AND NUIS STATEMENT							
TYPE	SIZE (IN MM)	QUANTITY					
		VIEW P3	PLAN B-B				
В	ø 16X35	52	26				
C	ø 16X40	8	38				
D	ø 16X45	-	_				
E	ø 16X50	-	-				
F	ø 16X55	-	-				
G	ø 16X60	•	-				
Н	ø 16X65	•	-				
J	ø 16X70	-	-				
K	ø 16X75	•	-				
L	<b>≠</b> 16X80	-	_				
SPRING WASHERS		60	64				
30 O.D PACKING WASHERS Ø 17.5 MM							
	5 mm	_					

## GENERAL NOTES:

- ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE SPECIFIED.

  ALL STEEL BOLT AND NUTS TO ISS638/12427/5.6 OLTY
- 2. MILD STEEL BOLT AND NUTS TO ES658/12427/5.6 QLTY
  3. ALL MILD STEEL BOLT AND NUTS ARE TO BE HOT DIP GALVANISED
- 4. ALL MILD STEEL SECTIONS SHALL BE OF TESTED QUALITY CONFORM
- GALVANATION OF TOWER MEMBERS AND FLAT
- ♦ ALL HOLES # 17.5mm FOR #18mm STEP BOLTS STANDARD SPRING WASHERS ARE TO BE USED UNDER I

MARK NO: 435 + 444 & 461 + 464

## BIHAR STATE POWER TRANSMISSION COMPANY LTD

DRAWN BY	DESCRIPTION  220KV D/C TOWER TYPE "2DC" (±0Mtr BASE &+3Mtr EXTN.)		SCALE			
CHECKED BY		VIEW AT P3 & PLAN VIEW A-A			-	
APPROVED BY	DRG NO	220KV-D/C-Struct-±0M-Base- +3M-Extn -39	SHEET NO 1-1	REV.	0	